

Herz Fig No 4000

Screwed Fixed Orifice Metering Stations DN15 – DN50 shall be DZR Copper Alloy and shall have an orifice integral to the valve body and be in accordance with BS7350, rated PN20, with female thread on the upstream side of the orifice and male thread on the downstream side. Metering stations will be fitted with self-sealing test points for differential pressure measurement. Valves must be sized for the flow rate required for each application, low and medium flow versions will be available. The valve manufacturer shall provide a five year fully comprehensive warranty, covering parts, labour and consequential loss.