

Herz Fig No 9460 & 9430

Thermostatic sensors to be liquid filled and have the ability to limit, or lock the set temperature. Heads shall have remote sensors with 2m and 8m capillaries and have automatic frost protection at 6°C. Sensor temperature range should be 6 – 28°C with frost set closure and 0 – 30°C with mechanical shut off. The valve manufacturer shall provide a five year fully comprehensive warranty, covering parts, labour and consequential loss.