## Herz Fig No 9260 & 9230

Design thermostatic sensors to be liquid filled and have the ability to limit, or lock the set temperature. Sensors shall be of the fixed integral type and have automatic frost protection at 6°C. Sensor temperature range should be  $6 - 28^{\circ}$ C with frost set closure and  $0 - 30^{\circ}$ C with mechanical shut off. The valve manufacturer shall provide a five year fully comprehensive warranty, covering parts, labour and consequential loss.