

Herz Fig No 4011

WRAS Approved Hot water services return thermal balancing, circuit temperature controllers (CTC) shall be DZR Copper alloy and of the non-adjustable, twin piston type in either DN15 or DN20 sizes, rated PN10. The control piston shall be set to 55°C for normal HWS circulation and the secondary piston set at 70°C to allow anti-Legionella pasteurisation to be carried out. The valve manufacturer shall provide a five year fully comprehensive warranty, covering parts, labour and consequential loss.